



NOTES

1. PROVIDE DISTRICT APPROVED SUPPORT AND OUTSIDE ENCLOSURES FOR ASSEMBLIES LARGER THAN 2" DIAMETER
2. OWNER SHALL FURNISH, INSTALL, TEST AND MAINTAIN THE RPBA AND ALL PIPING AND APPURTENANCES SHOWN ON THIS PLAN. THE RPBA SHALL BE ACCESSIBLE TO THE DISTRICT AT ALL TIMES
3. THE ASSEMBLY MUST BE PROTECTED FROM FREEZING, OTHER SEVERE WEATHER, AND FROM ACCIDENTAL DAMAGE. (ALSO LOCATED IMMEDIATELY BACK OF METER)
4. DRAIN SHALL BE SIZED IN ACCORDANCE WITH AWWA CROSS CONNECTION CONTROL MANUAL 6-8.
5. RPBA MUST BE ON WASHINGTON STATE DOH APPROVED LIST, MUST BE TESTED UPON INSTALLATION BY A WASHINGTON STATE CERTIFIED BACKFLOW ASSEMBLY TESTER, INSTALLED PER MANUFACTURER SPECS TO RETAIN WARRANTIES, AND MUST BE TESTED ANNUALLY THEREAFTER. SUCCESSFUL TEST RESULT MUST BE REPORTED ANNUALLY TO THE DISTRICT.
6. RPBA MUST BE TESTED IF MOVED OR REPAIRED.
7. FACILITY IS OWNED AND MAINTAINED BY PROPERTY OWNER FOLLOWING CONSTRUCTION.
8. NOTE DISTRICT'S PREMISE ISOLATION PROGRAM REQUIREMENTS (MANUAL ONLINE)

LAST REVISED	07/16
APPROVED BY	
STEVE LEE	12/16
ENGINEER	



REDUCED PRESSURE
BACKFLOW ASSEMBLY
(RPBA)

20